

7/11
8-12-13

AUG 12 2013

August 12, 2013

To: Wm. Oakley Hall at TDEC

From: Tommy Buford at Baxter, TN WWTP, Permit Number **TN0021121**

Re: Written Overflow Notification

A 6.00" rainfall event caused heavy infiltration in Baxter's collection system. As a result of this rainfall event Baxter had one wet weather overflow at the wet-well to our plant pump station that is situated about 50' from Mine Lick Creek. This pump station is the last pump station in our collection system and it pumps all of the town's wastewater to the WWTP.

The overflow started at about noon on Thursday, August 8 and continued until about 9:00pm on Thursday, August 8. The duration of the overflow was about nine hours. Approximately 30,000 gallons overflowed.

During the overflow bales of wheat straw were in place at the wet-well in order to prevent solids from reaching Mine Lick Creek. All debris will be raked up and disposed of and agricultural lime will be applied to prevent possible odors at the overflow site.

If you have questions or need additional information please contact me at 931-858-3348. Thank you.

Tommy Buford
8-12-13